



Hicksville Water District

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER Deferral Issued for PFOA, PFOS and 1,4-Dioxane at Hicksville Water District

Why are you receiving this notice/information?

You are receiving this notice because testing of our public water system found the chemicals perfluorooctanoic acid (PFOA), perfluorooctanesulfonic acid (PFOS) and 1,4-Dioxane in your drinking water above New York State's maximum contaminant level (MCL) of 10 ppt for PFOA/PFOS and 1 ppb for 1,4-dioxane. The MCLs are set well below levels known to cause health effects in animal studies. Therefore, consuming water with PFOA, PFOS or 1,4-dioxane at the level detected does not pose a significant health risk. Your water continues to be acceptable for all uses.

The Hicksville Water District has submitted, and the New York State Department of Health (Department) has issued, a deferral to the Hicksville Water District. When a public water system is issued a deferral, the water system agrees to a schedule for corrective action and compliance with the new MCLs. In exchange, the Department agrees to defer enforcement actions, such as assessing fines, if the water district is meeting the established deadlines. We are required to update the Department and the Nassau County Department of Health each calendar quarter on the status of our projects. If we do not meet the agreed upon deadlines, the Department can resume enforcement.

What are the health effects of PFOA/PFOS?

The available information on the health effects associated with PFOA/PFOS, like many chemicals, comes from studies of high-level exposure in animals or humans. Less is known about the chances of health effects occurring from lower levels of exposure, such as those that might occur in drinking water. As a result, finding lower levels of chemicals in drinking water prompts water suppliers and regulators to take precautions that include notifying consumers and steps to reduce exposure.

PFOA and PFOS has caused a wide range of health effects when studied in animals that were exposed to high levels. Additional studies of high-level exposures of PFOA and PFOS in people provide evidence that some of the health effects seen in animals may also occur in humans. The most consistent findings in animals were effects on the liver and immune system and impaired fetal growth and development. The United States Environmental Protection Agency considers PFOA and PFOS as having suggestive evidence for causing cancer based on studies of animals exposed to high levels of this chemical over their entire lifetimes.

At the level of PFOA and PFOS detected in your water, exposure from drinking water and food preparation is well below PFOA and PFOS exposures associated with health effects.

What are the health effects of 1,4-dioxane?

Laboratory studies show that 1,4-dioxane caused liver cancer in animals exposed at high levels throughout their lifetime. Other types of cancer have also been reported, although less consistently than liver cancer. There is no evidence of 1,4-dioxane cancer effects in humans. The United States Environmental Protection Agency considers 1,4-dioxane a likely human



Hicksville Water District

carcinogen based upon studies of animals exposed to high levels of this chemical over their entire lifetimes.

At the level of 1,4-dioxane detected in your water, exposure from drinking water and food preparation is well below 1,4-dioxane exposures associated with health effects.

What is New York State doing about PFOA, PFOS and 1,4-Dioxane in public drinking water?

The New York State Department of Health (NYS DOH) has adopted a drinking water regulation that requires all public water systems to test for PFOA, PFOS and 1,4-dioxane. If found above the MCLs, the water supplier must take steps to lower the level to meet the standard. Exceedances of the MCL signal that steps should be taken by the water system to reduce contaminant levels.

What is being done to remove these contaminants?

Despite the challenges of the pandemic and current supply chain issues, the Hicksville Water District has undertaken immediate and determined action to install treatment systems for the removal of 1,4 -dioxane, PFOA and PFAS at all impacted facilities in excess of current regulatory limits. Treatment systems have been successfully commissioned at our Plants 1, 4, 5 and 9. Construction of a wellhead treatment system is underway at our Plant 8. The impacted Plant 8 supply wells have been out of service since September 2021. The project is scheduled to be completed by September 2023.

Additional information will be shared as further testing and progress occurs. This process is similar for any chemical detected in public drinking water that requires mitigation. The compliance timetable will ensure that your drinking water will meet the MCL as rapidly as possible. The deferral is effective until August 25, 2023.

Where can I get more information?

For more information, please contact Paul J. Granger, P.E.; Superintendent of the Hicksville Water District at Phone:516.931.0184 or e-mail: info@hicksvillewater.org

You can also contact the Nassau County Department of Health, Office of Public Water Supply Protection and Groundwater Assessment at (516) 227-9692.

If you have additional questions about these contaminants and your health, talk to your health care provider who is most familiar with your health history and can provide advice and assistance about understanding how drinking water may affect your personal health.

Public Water System ID# NY2902829

Hicksville Water District
4 Dean Street
Hicksville, NY 11801

Date: September 6, 2022